

BATTERY INSTALLATION GUIDE

Natural Gas Alarm: Model ML-310ES

WARNING! Battery Not Connected. See diagram to connect battery with wires. Natural Gas alarm will not operate unless battery is properly installed.

DO NOT REMOVE PLASTIC SURROUNDING THE BATTERY PACK.


CONNECT BATTERIES by inserting battery harness plug into the Gas Alarm as shown.

WATCH for green Power light on front of Gas Alarm to blink for 30 seconds and then stop. **LISTEN** for one beep after green Power light stops to confirm Gas Alarm has completed power-on cycle.

TEST GAS ALARM. Press and hold the test button for 5 seconds. If the Gas Alarm is operating properly, the red light on the front of the Gas Alarm will blink once every 2 seconds for a 12-second period, and you will hear four beeps: *Beep Beep Beep Beep*, and a recorded message:

"Danger. Gas leak explosion risk. Evacuate, then call 911."

"Peligro. Riesgo de explosión por fuga de gas. Evacuar, luego llamar al 911."



DeNova Detect®
Smarter Gas Leak Safety

MOUNT GAS ALARM in every room with a gas appliance—between 3 and 10 feet away from the gas appliance. Gas Alarms should be within 12 inches from the ceiling—where natural gas accumulates first.

CONSULT MODEL ML-310ES USER'S MANUAL for complete instructions and important safety information.



Scan the code to view the
ALARM SETUP VIDEO

DeNova Detect[®]

Smarter Gas Leak Safety

847.749.3064

support@denovadetect.com

www.denovadetect.com

650 Warrenville Road, Suite 101, Lisle, IL 60532 USA